



THIS DRG IS THE SOLE PROPERTY OF ECS PVT. LTD.  
UNAUTHORISED USE OF THIS DRG OR MAKING PRODUCT AS PER OUR DRG  
WITHOUT OUR PERMISSION OR ANY OTHER MISUSE IS NOT PERMITTED.



S. NO.	DESCRIPTION	QTY
1.	STRAIGHT LENGTH (MTS)	
2.	RIGHT ANGLE BEND	2
3.	PHASE CROSSOVER CHAMBER	1
4.	FLANGE AT TRANSFORMER END	1
5.	FLANGE AT PANEL END	1
6.	AL. FLEXIBLE	2
7.	COPPER FLEXIBLE	NIL
8.	240V, 40W SPACE HEATER	2
9.	30-90°C THERMOSTAT	1
10.	6A, DP, MCB	1

- FOR GENERAL NOTES, REFER DRG. NO 941-100-01

				CLIENT	M/S L&T	DRN.	AKS	28.2.94		ELECTRIC CONTROLS & SWITCHBOARDS (P) LTD. D-6, SEC.VIII, NOIDA-201 301 (U.P.)		
						CHD.	ANQ	28.2.94				
				CONSULTANT	M/S N.T.P.C.	APPD.			TITLE G.A. DRG 2500A BUS DUCT BETWEEN TR-1 AND 1F OF STN. SERVICE SW. GR.			
						SCALE	N.T.S.					
REV NO	DATE	DRN	REVISION	PROJECT	BADARPUR THERMAL POWER STATION, N.T.P.C.	JOB NO.	941		DRG. NO.	941-101-01		SHEET 1 OF 1
						TOTAL SHT	OF					