



DESCRIPTION		SYMBOL	DESCRIPTION		SYMBOL	DESCRIPTION		SYMBOL	DESCRIPTION		SYMBOL
TKC 24/236	-		TCX 23/236	-		EMG. LIGHT FCS 31/211 (F)	-		SIGN LAMP SINGLE FACE ON DOOR	-	
TMC 55/236	-		TMA 30/118	-		EMG. LIGHT FCS 31/211 (O)	-		SIGN LAMP SINGLE FACE WITH DOUBLE ARROW	-	
TMC 21/136	-		DN613	-		LIGHT CONTROL CENTRE	-		SIGN LAMP SINGLE FACE WITH SINGLE ARROW	-	
TMC 30/118	-		FCM 01	-		SWITCH BOX	-		SIGN LAMP DOUBLE FACE WITH DOUBLE ARROW	-	
TDC 10/236	-		EXHAUST FAN	-		RECEPTACLE 2x16A	-		SIGN LAMP DOUBLE FACE WITH SINGLE ARROW	-	
TBS 30/236	-		CEILING FAN	-		RECEPTACLE (63A+16A)	-		150W HPSV BRACKET MOUNTED LIGHT	-	
TCS 19/218	-					WIRE WAY DUCT	-				

- NOTES:-
- 6 B L4 LCC NO.4 B PHASE CIRCUIT NO. OF LCC
 - LCC SHALL BE MOUNTED AT 800 MM. FROM F.F.L. ON WALL / COLUMN.
 - WIRE WAY DUCT SHALL BE SUPPORTED AS SHOWN
 - CONNECTION FROM EACH LCC TO WIREWAY DUCT SHALL BE THROUGH CONDUITS EMBEDDED IN WALL.
 - SWITCH BOX SHALL BE MOUNTED AT 1.2M FROM FFL.
 - ALL RECEPTACLE SHALL BE MOUNTED AT 0.3M FROM FFL.
 - SEPERATE SWITCH SHALL BE PROVIDED FOR EACH EXHAUST FAN.
 - 3 B LE1 EMERGENCY LIGHTING PANEL NO.1 B PHASE CIRCUIT NO. OF LCC
 - SIGN. LAMPS SHALL BE FIXED AT 3.00 M. FROM F.F.L.

DRAWING NO.	REFERENCE DRAWING

REV. NO.	DATE	REVISIONS	BY	CHK	DEPT. HEAD	CHIEF ENGR.	PROJ. MGR.
1	08.10.96	GENERALLY REVISED			P.T. AKC	K.I.	
0	04.08.96	ISSUED FOR APPROVAL			P.T. AKC	K.I.	

LIGHTING LAYOUT : FACTORY AREA

Y. K. K. INDIA PVT. LTD. BAWAL (HARYANA)

Diverse Enterprises Pvt. Ltd. Engineers & Consultants New Delhi

7005-LLA-03 (SHT. 1 OF 2)

1