



NOTES:

- FOR NOTES AND LEGENDS REFER DRAWING NO. 7005-LLA-03 SH. 1 OF 2
TITLED LIGHTING LAYOUT : FACTORY AREA
- OFFICE LIGHTING TO BE DONE THROUGH 25MM DIA G.I. CONDUIT TO BE EMBEDDED IN WALL / LAID ABOVE FALSE CEILING.

INDOOR SPLIT UNIT A/C. WIRING TO BE TERMINATED AT MCCB TO BE PROVIDED BY A/C SUPPLIER

AHU UNIT. WIRING TO BE TERMINATED AT AHU CONTROL UNIT

| DRAWING NO. | REFERENCE DRAWING |
|-------------|-------------------|
| | |
| | |
| | |
| | |
| | |

| REV. NO. | DATE | REVISIONS | BY | CHK | DEPT. HEAD | CHIEF ENGR. | PROJ. MGR. |
|----------|------|------------------------------------|----|-----|------------|-------------|------------|
| 1 | 27.9 | OFFICE LAYOUT CHANGE INCORPORATED. | | | | | |

LIGHTING LAYOUT : OFFICE

Y. K. K. INDIA PVT. LTD.

BAWAL (HARYANA)

DEPL
Diverse Enterprises Pvt. Ltd.
Engineers & Consultants
New Delhi

7005-LLA-04

REV.

1

Y K K

SCALE = 1:125